

# DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

## SANITARY CERTIFICATE

(Under the Tamilnadu Education Rules)

Appendix-3

(Chapter III Rules - 24 )

I hereby declare that I have inspected the **THE PSBB MILLENNIUM SCHOOL**, building and premises located at DLF Garden City, Thazhambur, Off.OMR, Chennai-600 130, Thiruporur Block, Chengalpattu District has been inspected on **Friday 19<sup>th</sup> July 2024** and has been found,

- ❖ That the accommodation provided foreach of the several divisionsis sufficient and it is properly ventilated and lighted
- ❖ That the building is maintained in substantial repair and is neat and clean.
- ❖ That the supply of drinking water is wholesome and safe
- ❖ That the premises is free from mosquito and housefly nuisance.
- ❖ That the building is ratproof and has proper drainage.
- ❖ First aid kit box is kept ready with drugs for use and maintained by a responsible person.
- ❖ That the liquid and solid wastages are disposed of in a sanitary manner.
- ❖ That the latrine and urinal arrangements are adequate for both sex and good
- ❖ That in all other necessary aspects the sanitation is good.

### Conditions:

- ❖ The Authority should follow the COVID-19 Rules like Social Distance, Wearing Facemask, Provision of Hand Wash.
- ❖ The Authority should ban Cigarette and other tobacco products inthe campus and visible board to be displayed -COTP Act 2003.
- ❖ The certificate is valid for one year from the date of issue.

L. Dis. No: **4892/A2/2024**

Dated: **22-07-2024**

**Block Health Supervisor**

Thiruporur Block

Kelambakkam- 603 103



Counter Signed

*[Handwritten signature]*

District Health Officer  
Chengalpattu district

*[Handwritten signature]*

**PRINCIPAL**

The PSBB Millennium School  
DLF Garden City Thazhambur,  
Off OMR, Chennai - 600 130  
Ph. +91 - 44 - 48517880 / 7901

To,  
**THE PSBB MILLENNIUM SCHOOL**,  
DLF Garden City, Thazhambur, Off.OMR,  
Chennai-600 130, Thiruporur Block, Chengalpattu District.



TC-7210

**CALI-LABS PVT. LTD.**

A HOUSE OF CALIBRATION AND TESTING

Address & Lab Location :

Khasra No. 11/1/1/1/2/2 Infront of Govt. School  
Lambakheda, Berasia Road, Bhopal (M.P.) 462 038  
Tel. 9981139888 | e-mail callilabs@gmail.com  
Website : www.callilabs.in

GST No.: 23AABCC4713G127

**TEST REPORT**

UNIQUE LAB REPORT : ULR - TC721024000007355F  
SERVICE REQUEST No. : CL/CLT/1081/2024  
TEST REPORT No. : 4398/10/05/2024

1. Chemical Testing  
1. Water - Packaged Drinking Water

Form No. : CL/F/34  
Sheet No. : 1 of 1  
Date of issue : 08.06.2024

REPORT ISSUED To : M/s. SUGAR TIRTH AGRO FOODS  
No. 3, Leo Crusher Estate,  
Karanal Main Road,  
Arasankazhani, Chennai - 600 130



SAMPLE DESCRIPTION : PACKAGED DRINKING WATER

TEST METHOD REF.	: IS : 14543 : 2016 with amendment no. 8		
GRADE / VARIETY/TYPE/CLASS / SIZE, etc.	: PACKAGED DRINKING WATER		
BRAND NAME, IF ANY	: Not Declared	DECLARED VALUE, IF ANY	: Not Applicable
QUANTITY & PACKING	BATCH NO.	DOM	DOE
1 l x 4 bottle	2	02.05.2024	01.11.2024
DATE OF RECEIPT	DATE OF START ANALYSIS	: 20.05.2024	
17.05.2024	DATE OF COMPLETION OF ANALYSIS	: 05.06.2024	
ANY OTHER INFORMATION	Six monthly tests as per STI of IS : 14543 : 2016, except Bromate		

Sl. No.	TESTS	UNIT OF MEASUREMENT	LIMIT	RESULTS	TEST METHOD REF.
<b>Table - 2 General Parameters concerning substances undesirable in excessive amounts</b>					
vii)	Fluoride as F	mg/l	1.0 Max.	0.8	APHA : 4500 (24 <sup>th</sup> Edition)
ix)	Silver as Ag	mg/l	0.01 Max.	BDL (DL-0.005)	IS:3025 (Pt. 2) : 2019
xii)	Selenium as Se	mg/l	0.01 Max.	BDL (DL-0.002)	IS:3025 (Pt. 2) : 2019
xvii)	Sodium as Na	mg/l	200 Max.	9.900	IS:3025 (Pt. 2) : 2019
<b>Table - 3 Parameters concerning Toxic substances</b>					
i)	Mercury as Hg	mg/l	0.001 Max.	BDL (DL-0.0002)	IS:3025 (Pt. 2) : 2019
ii)	Cadmium as Cd	mg/l	0.003 Max.	BDL (DL-0.001)	IS:3025 (Pt. 2) : 2019
iii)	Arsenic as As	mg/l	0.01 Max.	BDL (DL-0.002)	IS:3025 (Pt. 2) : 2019
iv)	Cyanide as CN	mg/l	Absent	Absent	IS:3025 (Pt.-27) Sec.-1 : 2021
v)	Lead as Pb	mg/l	0.01 Max.	BDL (DL-0.010)	IS:3025 (Pt. 2) : 2019
vi)	Chromium as Cr	mg/l	0.05 Max.	BDL (DL-0.005)	IS:3025 (Pt. 2) : 2019
vii)	Nickel as Ni	mg/l	0.02 Max.	BDL (DL-0.005)	IS:3025 (Pt. 2) : 2019
viii)	Poly Chlorinated Biphenyls (PCB)	-	ND	ND	APHA : 6431 C (24 <sup>th</sup> Edition)
ix)	Polynuclear Aromatic Hydrocarbons (PAH)	-	ND	ND	APHA : 6440 C (24 <sup>th</sup> Edition)

Note :- BDL - Below Detection Limit

DL - Detection Limit

ND - Not Detected

**REMARK :**

- Sample tested as per IS : 14543 : 2016 with amendment no. 8
- This report, in full or in part, shall not be published, advertised, used for any legal action, unless prior permission has been secured from The Director, CALI-LABS PVT.LTD. BHOPAL.
- The test report pertains to the sample tested.
- Sample not drawn by us.

(Analyst)

*S. Anuman*

PRINCIPAL

The PSBB Millennium School  
DLF Garden City Thazhambur,  
Off OMR, Chennai - 600 130.  
Ph. +91 - 44 - 43517880 / 7901



(Pooja Pandey)  
Technical Manager  
Authorised Signatory